

# CERTIFICATE OF CONFORMITY

This Certificate is issued to  
**DELTA TECHNOLOGY PTE LTD**  
**No. 34 Loyang Crescent**  
**Singapore 508993**

**For Product Certification Scheme: Type 1b**

**Product** : **Fire Rated Shutter**

**Brand** : **Delta Technology**

**Model** : **LFRS-240**

**Country of Origin** : **Singapore**

**Product Details** : **An un-insulated curved single-screen lateral sliding shutter.**  
**Max. vision shutter size : 70m (W) x 8m (H)**  
**Refer to Appendix for more details.**  
**Integrity : 240 mins**

which has complied with the requirements of the scheme based on the following:

<b>STANDARD(S)</b>	<b>TEST REPORT(S)</b>
EN 1634-1: 2014	RED Test Report No.: R19B08-1A RED Assessment Report No.: R19F33-1A



**Dixon Ng (Mr)**  
Program Manager  
SETSCO Services Pte Ltd  
18 Teban Gardens Crescent  
Singapore 608925

**Certificate No**  
**FSP-2016-0341**

**Date of Issue**  
**06/01/2020**

**Date of Expiry**  
**01/06/2024**

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at [www.setsco.com](http://www.setsco.com)

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.