CERTIFICATE OF CONFORMITY

This Certificate is issued to

DELTA TECHNOLOGY PTE LTD 34 Loyang Crescent Singapore 508993

For Product Certification Scheme: Type 1b

Product

Fire Rated Curtain

Brand

Delta Technology

Model

IFRC 240

Country of Origin

Singapore

Product Details

A fully insulated double-screen vertical sliding roller shutter

Overall Size: 15,000mm (W) x 8,000mm (H) Integrity: 240 mins: Insulation: 240 mins

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

TEST REPORT(S)

BS EN 1634-1: 2014

RED Test Report No.: R18L33-1A

RED Assessment Report No.: R19A09-1A

Sze Thiam Siong (Mr)
Chief Executive Officer
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No

Date of Issue

Date of Expiry

FSP-2015-0287

05/03/2019

12/11/2023



This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.